

| 日立照明器具 照明特性 | | | | | | | | | | | | | | | | | | | | | | | |
|------------------------|----------------------------------|-------------|------|------|------|------|------|------|------|------|------|------|------|------|--|--|--|--|--|--|--|--|--|
| 名称: 直管形LEDランプ | 反射率 | 天井 | 80% | | | 70% | | | 50% | | | 30% | | 0% | | | | | | | | | |
| | 壁 | 70% | 50% | 30% | 70% | 50% | 30% | 10% | 50% | 30% | 10% | 50% | 30% | 0% | | | | | | | | | |
| | 床 | | | | 10% | | | | | | 0% | | | | | | | | | | | | |
| 形式: LDK110SS-N/42/69NE | 室指数 | 照明率 S/H=1.0 | | | | | | | | | | | | | | | | | | | | | |
| | <備考> FLR110形 定格出力タイプ (昼白色) | | | | | | | | | | | | | | | | | | | | | | |
| 姿図 | 0.6 | 0.52 | 0.40 | 0.32 | 0.50 | 0.39 | 0.31 | 0.26 | 0.36 | 0.30 | 0.25 | 0.34 | 0.28 | 0.24 | | | | | | | | | |
| | 0.8 | 0.61 | 0.49 | 0.41 | 0.59 | 0.48 | 0.40 | 0.34 | 0.45 | 0.38 | 0.33 | 0.42 | 0.36 | 0.31 | | | | | | | | | |
| | 1 | 0.67 | 0.56 | 0.48 | 0.65 | 0.54 | 0.46 | 0.40 | 0.50 | 0.44 | 0.39 | 0.47 | 0.41 | 0.37 | | | | | | | | | |
| | 1.25 | 0.73 | 0.62 | 0.54 | 0.70 | 0.60 | 0.53 | 0.47 | 0.56 | 0.50 | 0.45 | 0.53 | 0.47 | 0.43 | | | | | | | | | |
| | 1.5 | 0.77 | 0.68 | 0.60 | 0.74 | 0.65 | 0.58 | 0.52 | 0.61 | 0.55 | 0.50 | 0.57 | 0.52 | 0.48 | | | | | | | | | |
| | 2 | 0.83 | 0.75 | 0.68 | 0.80 | 0.72 | 0.66 | 0.60 | 0.67 | 0.62 | 0.57 | 0.63 | 0.58 | 0.55 | | | | | | | | | |
| | 2.5 | 0.87 | 0.79 | 0.73 | 0.83 | 0.77 | 0.71 | 0.66 | 0.72 | 0.67 | 0.62 | 0.67 | 0.63 | 0.59 | | | | | | | | | |
| 光源 | 3 | 0.89 | 0.82 | 0.77 | 0.86 | 0.80 | 0.74 | 0.70 | 0.75 | 0.70 | 0.66 | 0.70 | 0.66 | 0.63 | | | | | | | | | |
| | 4 | 0.92 | 0.87 | 0.82 | 0.89 | 0.84 | 0.80 | 0.76 | 0.79 | 0.75 | 0.72 | 0.74 | 0.71 | 0.68 | | | | | | | | | |
| 品名 | 直管形LEDランプ | 5 | 0.95 | 0.90 | 0.86 | 0.91 | 0.87 | 0.83 | 0.80 | 0.82 | 0.78 | 0.75 | 0.76 | 0.74 | | | | | | | | | |
| 形式 | LDK110SS-N/42/69NE | 7 | 0.97 | 0.94 | 0.91 | 0.94 | 0.91 | 0.88 | 0.85 | 0.85 | 0.83 | 0.81 | 0.80 | 0.78 | | | | | | | | | |
| 光束 | 6,950 lm | 10 | 1.00 | 0.97 | 0.95 | 0.96 | 0.94 | 0.92 | 0.90 | 0.88 | 0.87 | 0.85 | 0.83 | 0.80 | | | | | | | | | |
| 器具効率 Ft= | | | | | | | | | | | | | | | | | | | | | | | |
| 上方光束 Fu= | | | | | | | | | | | | | | | | | | | | | | | |
| 下方光束 Fd= | | | | | | | | | | | | | | | | | | | | | | | |
| 最大取付間隔 | | | | | | | | | | | | | | | | | | | | | | | |
| A-A | | 1.36 H | | | | | | | | | | | | | | | | | | | | | |
| B-B | | 1.28 H | | | | | | | | | | | | | | | | | | | | | |
| 保守率 | 良 | | | | | | | | | | | | | | | | | | | | | | |
| 中 | | | | | | | | | | | | | | | | | | | | | | | |
| 否 | | | | | | | | | | | | | | | | | | | | | | | |
| 光度 (cd/1000 lm) | | | | | | | | | | | | | | | | | | | | | | | |
| | A-0 | B-B | C-0 | A'-0 | C'-0 | | | | | | | | | | | | | | | | | | |
| 0 | 228 | 228 | 228 | | | | | | | | | | | | | | | | | | | | |
| 10 | 225 | 223 | 224 | | | | | | | | | | | | | | | | | | | | |
| 20 | 217 | 212 | 215 | | | | | | | | | | | | | | | | | | | | |
| 30 | 205 | 195 | 200 | | | | | | | | | | | | | | | | | | | | |
| 40 | 189 | 170 | 180 | | | | | | | | | | | | | | | | | | | | |
| 50 | 170 | 138 | 157 | | | | | | | | | | | | | | | | | | | | |
| 60 | 150 | 103 | 130 | | | | | | | | | | | | | | | | | | | | |
| 70 | 130 | 63 | 105 | | | | | | | | | | | | | | | | | | | | |
| 80 | 109 | 31 | 80 | | | | | | | | | | | | | | | | | | | | |
| 90 | 91 | 3 | 60 | | | | | | | | | | | | | | | | | | | | |
| 100 | 74 | 2 | 46 | | | | | | | | | | | | | | | | | | | | |
| 110 | 57 | 3 | 34 | | | | | | | | | | | | | | | | | | | | |
| 120 | 44 | 4 | 25 | | | | | | | | | | | | | | | | | | | | |
| 130 | 32 | 6 | 19 | | | | | | | | | | | | | | | | | | | | |
| 140 | 23 | 6 | 15 | | | | | | | | | | | | | | | | | | | | |
| 150 | 16 | 7 | 12 | | | | | | | | | | | | | | | | | | | | |
| 160 | 12 | 8 | 10 | | | | | | | | | | | | | | | | | | | | |
| 170 | 9 | 8 | 9 | | | | | | | | | | | | | | | | | | | | |
| 180 | 8 | 8 | 8 | | | | | | | | | | | | | | | | | | | | |

