

日立照明器具 照明特性

| 名称: 交換形LED逆富士形 | 反射率 | 天井 | 80% | | | 70% | | | 50% | | | 30% | | | 0% | | | |
|-----------------|-----|-------------------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|------|--|
| | | 壁 | 70% | 50% | 30% | 70% | 50% | 30% | 10% | 50% | 30% | 10% | 50% | 30% | 10% | 0% | | |
| | | 床 | 10% | | | | | | | | | | | | 0% | | | |
| 形式: NC4ACP | | 室指数 固有照明率 S/H=1.0 | | | | | | | | | | | | | | | | |
| <備考> キャビースイッチ付 | | 0.6 | 0.56 | 0.44 | 0.37 | 0.55 | 0.44 | 0.36 | 0.31 | 0.42 | 0.36 | 0.31 | 0.41 | 0.35 | 0.31 | 0.28 | | |
| | | 0.8 | 0.66 | 0.54 | 0.46 | 0.64 | 0.53 | 0.46 | 0.40 | 0.51 | 0.45 | 0.40 | 0.50 | 0.44 | 0.39 | 0.37 | | |
| 姿図 | | 1 | 0.72 | 0.61 | 0.53 | 0.70 | 0.60 | 0.53 | 0.47 | 0.58 | 0.51 | 0.46 | 0.56 | 0.50 | 0.46 | 0.43 | | |
| | | 1.25 | 0.77 | 0.67 | 0.60 | 0.76 | 0.66 | 0.59 | 0.54 | 0.64 | 0.58 | 0.53 | 0.62 | 0.57 | 0.52 | 0.49 | | |
| | | 1.5 | 0.82 | 0.73 | 0.66 | 0.80 | 0.71 | 0.65 | 0.60 | 0.69 | 0.63 | 0.59 | 0.67 | 0.62 | 0.58 | 0.55 | | |
| | | 2 | 0.87 | 0.80 | 0.73 | 0.85 | 0.78 | 0.72 | 0.68 | 0.76 | 0.71 | 0.66 | 0.73 | 0.69 | 0.65 | 0.62 | | |
| | | 2.5 | 0.91 | 0.84 | 0.78 | 0.89 | 0.83 | 0.77 | 0.73 | 0.80 | 0.75 | 0.71 | 0.77 | 0.73 | 0.70 | 0.67 | | |
| | | 3 | 0.93 | 0.87 | 0.82 | 0.91 | 0.86 | 0.81 | 0.77 | 0.83 | 0.79 | 0.75 | 0.80 | 0.77 | 0.74 | 0.70 | | |
| 光源形式 | | 4 | 0.96 | 0.91 | 0.87 | 0.94 | 0.90 | 0.86 | 0.82 | 0.87 | 0.83 | 0.80 | 0.84 | 0.81 | 0.79 | 0.75 | | |
| | | 5 | 0.98 | 0.94 | 0.90 | 0.96 | 0.93 | 0.89 | 0.86 | 0.90 | 0.87 | 0.84 | 0.87 | 0.84 | 0.82 | 0.79 | | |
| 器具光束 | | 7 | 1.01 | 0.98 | 0.95 | 0.99 | 0.96 | 0.94 | 0.91 | 0.93 | 0.91 | 0.89 | 0.90 | 0.89 | 0.87 | 0.83 | | |
| | | 5,500 lm | 10 | 1.03 | 1.01 | 0.99 | 1.01 | 0.99 | 0.97 | 0.95 | 0.96 | 0.95 | 0.93 | 0.93 | 0.92 | 0.91 | 0.87 | |
| 器具効率 Ft= 100% | | 単体照度分布(初期値) | | | | | | | | | | | | | | | | |
| | | | | | | | | | | | | | | | | | | |
| 上方光束 Fu= 3.3% | | | | | | | | | | | | | | | | | | |
| 下方光束 Fd= 96.7% | | | | | | | | | | | | | | | | | | |
| 最大取付間隔 | | | | | | | | | | | | | | | | | | |
| | | A-A 1.28 H | | | | | | | | | | | | | | | | |
| | | B-B 1.22 H | | | | | | | | | | | | | | | | |
| 保守率 | 良 | 0.88 | | | | | | | | | | | | | | | | |
| | 中 | 0.86 | | | | | | | | | | | | | | | | |
| | 否 | 0.81 | | | | | | | | | | | | | | | | |
| 光度 (cd/1000 lm) | | | | | | | | | | | | | | | | | | |
| | A-0 | B-B | C-0 | A'-0 | C'-0 | | | | | | | | | | | | | |
| 0 | 322 | 322 | 322 | | | | | | | | | | | | | | | |
| 10 | 317 | 317 | 317 | | | | | | | | | | | | | | | |
| 20 | 301 | 294 | 296 | | | | | | | | | | | | | | | |
| 30 | 272 | 262 | 271 | | | | | | | | | | | | | | | |
| 40 | 243 | 228 | 235 | | | | | | | | | | | | | | | |
| 50 | 192 | 170 | 184 | | | | | | | | | | | | | | | |
| 60 | 155 | 128 | 140 | | | | | | | | | | | | | | | |
| 70 | 122 | 83 | 102 | | | | | | | | | | | | | | | |
| 80 | 76 | 27 | 57 | | | | | | | | | | | | | | | |
| 90 | 47 | 1 | 30 | | | | | | | | | | | | | | | |
| 100 | 33 | 1 | 17 | | | | | | | | | | | | | | | |
| 110 | 4 | | | | | | | | | | | | | | | | | |
| 120 | | | | | | | | | | | | | | | | | | |
| 130 | | | | | | | | | | | | | | | | | | |
| 140 | | | | | | | | | | | | | | | | | | |
| 150 | | | | | | | | | | | | | | | | | | |
| 160 | | | | | | | | | | | | | | | | | | |
| 170 | | | | | | | | | | | | | | | | | | |
| 180 | | | | | | | | | | | | | | | | | | |